



## Caravan Sites and Control of Development Act 1960

# TOURING CARAVAN SITES

## STANDARDS



It will be a condition on site licences issued by this authority that sites must comply with the standards set out in this document.

All standards must be complied with to the satisfaction of the City Council.

Failure to comply with any of the standards is failure to comply with the conditions and may result in prosecution and revocation of the licence.

Clarification or further information regarding these standards may be obtained from:

Environmental Health Department  
Morecambe Town Hall  
Marine Rd  
Morecambe, LA4 5AF

Telephone: 01524 582935

Email: [environmentalhealth@lancaster.gov.uk](mailto:environmentalhealth@lancaster.gov.uk)

## **CONTENTS:**

1. Site Boundaries Density and Spacings
2. Parking
3. Roads, Gateways and Footpaths
4. Disabled Persons
5. Refuse Disposal
6. Telephone
7. Water Supply
8. Waste Water Disposal
9. Chemical Toilet Disposal
10. Toilet Facilities
11. Washbasins and Showers
12. Fire Points
13. Fire Hazards
14. Gas Installations / Equipment
15. LPG Stores
16. Electrical Installations
17. Play Equipment
18. Notices
19. Life Saving Equipment
20. General
21. Miscellaneous

## **1. SITE BOUNDARIES / DENSITY and SPACINGS**

- ❑ The boundaries of the site should be clearly marked, for example by fences or hedges.
- ❑ It is recommended that a 3 metre wide area should be kept clear within the inside of all boundaries.
- ❑ The site density should be consistent with Health and Safety and amenity requirements.
- ❑ The gross density should not exceed 30 units per acre (75 per hectare), calculated on the usable area (i.e. excluding lakes, roads, communal services and other areas unsuitable for the siting of caravans), rather than the total area.
- ❑ The minimum distance between vans in separate occupation should be at least **6 metres**.
- ❑ No caravan shall be less than **2 metres** from a site road.
- ❑ Where awnings are used there should still be a clear space of at least **3 metres** from the awning of one caravan to the next van in order to prevent fire spread.

## **2. PARKING**

- ❑ Vehicles and other equipment is permitted in the 6 metre space between caravans but in order to restrict the spread of fire there should always be **3 metres** clear space between caravans in separate occupation.

## **3. ROADS, VEHICLE GATEWAYS AND FOOTPATHS**

### **Roads shall:**

- ❑ be designed to provide adequate access for emergency vehicles
- ❑ be of suitable material
- ❑ be provided so that no caravan standing is more than 50 metres from a road
- ❑ be not less than 3.7 metres wide if a two-way system or 3 metres wide if a clearly marked one-way system.
- ❑ have no overhead cables less than 4.5 metres above the ground
- ❑ be kept clear for emergency vehicle access at all times
- ❑ be suitably lit at night as necessary

### **Vehicle Gateways shall:**

- ❑ be designed to give adequate access to emergency and other vehicles
- ❑ be a minimum of 3.1 metres wide
- ❑ have a minimum height clearance of 3.7 metres

### **Emergency Vehicles:**

- ❑ Should be able to gain access at all times to within 90 metres of any caravan on site.

## **Footpaths shall:**

- ❑ be provided between units and roads, roads and toilets blocks, and other communal buildings.
- ❑ be not less than 0.75 metres wide and provided with a hard surface
- ❑ be suitably lit at night as necessary

## **4. DISABLED PERSONS**

- ❑ On all new sites, water points, toilets, washing points and showers are to be designed in order to facilitate use by disabled persons.
- ❑ On existing sites, this requirement is to apply when any of the above facilities are altered or replaced.

## **5. REFUSE DISPOSAL**

- ❑ Adequate provision must be made for the storage, collection and disposal of refuse

## **6. TELEPHONE**

- ❑ Where practicable, a telephone should be provided on site. A notice by the telephone should include the address of the site.

## **7. WATER SUPPLY**

- ❑ All parks shall be provided with a water supply in accordance with appropriate Water Bylaws and statutory quality standards.
- ❑ No pitch should be more than **55 metres** from a water tap.
- ❑ Such water stand-pipes/taps should be clearly marked as '**DRINKING WATER**'
- ❑ A trapped gully shall be provided beneath each water tap.

## **8. WASTE WATER DISPOSAL**

- ❑ No pitch should be more than **55 metres** from a waste water disposal point.
- ❑ Waste water disposal points should be separate from Drinking Water points.

## **9. CHEMICAL TOILET DISPOSAL POINT**

- ❑ Properly designed chemical toilet disposal points shall be provided, with an adequate supply of water for cleaning the containers.
- ❑ The water supply must be marked '**NOT DRINKING WATER**' or '**WASTE WATER**'

## **10. TOILET FACILITIES**

- ❑ Sanitary facilities, with adequate supplies of water, shall be provided on at least the following scale:-

Men: 1 WC and 1 Urinal per 20 pitches

Women: 2 WC's per 20 pitches

Some variation on this standard may be allowed (e.g on sites with over 100 pitches) on discussion with the city council.

- ❑ Satisfactory provision should be made for foul drainage either by discharging to a public sewer, private sewer or sewage treatment works or to a septic tank or cesspool approved by the city council.

## **11. WASHBASINS AND SHOWERS**

- ❑ For every 30 caravans there should be 2 basins for men and 2 for women situated adjacent to the toilets.
- ❑ Showers with hot and cold running water should be provided on the scale of 1 shower for men and 1 for women per 25 pitches. Provision should be made for hanging clothes adjacent to each.
- ❑ An electric shaving socket should be provided in the mens facilities
- ❑ Suitable and sufficient artificial lighting must be provided to facilities.

## **12. FIRE POINTS**

**Fire fighting equipment and provision shall be in accordance with the requirements of the Fire Authority.**

**A general guide is set out below, if more detailed information is required please contact the local Fire Authority.**

- ❑ Every caravan shall be within **90 metres** of a fire point. The fire point shall be housed in a weather-proof structure (to protect it from frost), be easily accessible and clearly and conspicuously marked **FIRE POINT**.

**Each FIRE POINT should be provided with the following:**

### **FIRE FIGHTING EQUIPMENT: Either-**

- ❑ **HOSE REEL:** Where water stand-pipes are provided and there is sufficient water pressure to project a jet of water approx 5 metres: a hose reel complying with BS 5306: Part 11977 (1998) and a hose not less than 30 metres long terminating in a small hand control nozzle shall be provided.

Hoses should be housed in a box painted red and marked 'HOSE REEL'.

- ❑ **FIRE HYDRANTS:** Fire hydrants to BS 750 (1984) may be provided within 100 metres of every caravan standing.
- ❑ **FIRE EXTINGUISHERS/TANKS:** Where stand pipes are not provided or water pressure/flow is not sufficient, each Fire Point should be provided with either: 2 x 9 Litre water extinguishers or a water tank of at least 500 litres in capacity fitted with a hinged cover and provided with two buckets.

### **MEANS OF RAISING ALARM**

- ❑ Either a metal triangle with striker, a gong or hand operated siren should be provided to each fire point. The approval of the Fire Authority should be sought in respect of any alternative system.

### **FIRE NOTICE**

- ❑ A clearly written and conspicuous notice, protected from the weather, should be provided at each fire point to indicate the action to be taken in the event of a fire.
- ❑ The location of the nearest telephone should be included.

#### **The notice should include, at least, the following:**

“On discovering a fire:

- i) Ensure that the caravan or site building is evacuated
- ii) Raise the alarm
- iii) Call the Fire Brigade (the nearest telephone is situated.....)
- iv) Attack the fire using the fire fighting equipment, if it is safe to do so.

It is in the interest of all occupiers of the site to be familiar with the above routine and the method of operating the fire alarm and fire fighting equipment ”

### **MAINTENANCE OF FIRE POINTS**

- ❑ All alarm and fire equipment should be installed, tested and maintained in working order by a competent person at least once in every 12 months.
- ❑ A record of such tests and remedial action should be kept (e.g. log book or test certificate) and be available for inspection by/on behalf of the city council.

### **13. FIRE HAZARDS**

- ❑ Long grass, shrubbery and vegetation should be cut at regular intervals where necessary to prevent it becoming a fire hazard to caravans, buildings or other installations.
- ❑ Any cuttings should be removed from the vicinity of caravans.
- ❑ The space beneath and between caravans must not be used for the storage of combustible materials.

## **14. GAS INSTALLATIONS AND EQUIPMENT**

**These must comply with the relevant and applicable parts of the following:  
(or later guidance)**

- ❑ **For LPG supplied from cylinders:** LP Gas Association Code of Practice 7:1999  
“Storage of Full and Empty LPG Cylinders and Cartridges”
- ❑ **For LPG supplied by tanks:** LP Gas Association Code of Practice 1:  
Part 1: “Design, Installation and Operation of Vessels Located above Ground” AND  
Part 4: “Buried/Mounded LPG Storage Vessels”
- ❑ Any gas appliance provided on the site by the site operator must be safety checked by a CORGI registered engineer at least annually.
- ❑ A copy of all current safety check certificates required by gas safety legislation in respect of flues and appliances provided on the site by the site operator, shall be kept available for inspection by the licensing authority.
- ❑ Unless otherwise approved by the Local Authority every gas appliance provided on the site by the site operator shall be provided with an effective flame failure device.

## **15. LPG STORES**

Where LPG stores are provided on site for storage of LPG bottles the following should be provided:

- ❑ A lock to prevent unauthorised access to the store
- ❑ Adequate all round ventilation with no combustibles or drains in vicinity
- ❑ A ‘**NO SMOKING**’ sign
- ❑ A **FIRE POINT** with a dry powder fire extinguisher, alarm and fire notice

## **16. ELECTRICAL INSTALLATIONS**

- ❑ Where there is an electricity supply it shall meet all reasonable demands of the caravans.
- ❑ Installations, other than Electricity Company works and circuits subject to regulations made by the Secretary of State under Section 16 of the Energy Act 1983 and Section 64 of the Electricity Act 1947 : **Should be installed, tested and maintained in accordance with: British Standard 7671: 2001 “The Requirements for Electrical Installations”** (formally IEE Wiring Regs) for the time being in force, and where appropriate, to the standard which would be acceptable for the purposes of the ‘Electricity (Overhead Lines) Regs 1988, Statutory Instrument 1988 No 1057’.

Supplies to sites shall be inspected in accordance with the frequencies set out below and a Periodic Inspection Report in the form required by BS 7671:2001 shall be provided and displayed on site/retained by the site operator for inspection by the city council.

- ❑ Fixed Buildings (excluding licensed premises): **every 3 years**
- ❑ Licensed premises (liquor and entertainment) :**every year**
- ❑ Electrical distribution up to and including connection units on holiday home or mobile home parks (i.e.) statics: **every 3 years.**
- ❑ Electrical distribution up to and including electrical hook up points on touring parks: **every year**
- ❑ Hire fleet caravan holiday homes (park owned): **every 3 years**
- ❑ Hire fleet caravan holiday homes (owner/occupier but sub-let to park)- operator to ensure the owner provides the park operator with a current, satisfactory electrical certificate **every 3 years.**
- ❑ Street lighting: **every 3 years** (or 12 months if cables are overhead)
- ❑ Fire alarms and emergency lighting systems: **every year** with a documented quarterly check (not a certificate to BS7671) to ensure they are in working order.
- ❑ Park operators must carry out documented checks (not a certificate to BS7671) that all residual current devices are working properly **every 3 months.**

#### **Portable Electrical Equipment:**

- ❑ Portable electrical equipment in buildings or caravans under the control of the site operator should be examined (not necessarily by a qualified electrician) in accordance with HSE guidance "Maintaining Portable and Transportable Electrical Equipment" Ref: HS(G)107 available from HSE Books 01787 881165.
- ❑ See leaflet IND(G)237: available from LCC Environmental Health Department.

#### **Inspections/Work on installations:**

- ❑ All electrical installations shall be maintained to prevent danger as far as is practicable.
- ❑ Inspections or work on electrical supplies and installations shall be carried out by a competent person as required by BS7671:2001 (formally IEE Wiring Regs)
- ❑ If an installation does not comply with Regulations, applicable at the time it was first installed, it shall be rectified.
- ❑ Any major alterations and extensions to an installation shall comply with BS 7671:2001



## **17. PLAY EQUIPMENT**

- ❑ If play equipment is provided it should not be of the domestic type
- ❑ Equipment and playing surface (ground) material should meet the requirements of relevant British Standards, details of which should be available from the equipment manufacturer/installer.
- ❑ All equipment and the play surface should be maintained in sound/safe condition at all times
- ❑ A regular check should be made of all equipment and it is recommended that such checks be documented in a logbook.
- ❑ Regular visual checks for foreign objects, large stones, glass etc should be made
- ❑ Appropriate action should be taken if defects or hazards are found.
- ❑ Dogs should be excluded from designated children's play areas
- ❑ Ideally, designated play areas should be fenced off from the rest of the site and have a gate for access and enclosure.

## **18. NOTICES**

**The following signs/notices must be displayed in a conspicuous place:**

- ❑ A sign at the site entrance indicating the name of the site (for easy identification by emergency services)
- ❑ A copy of the site licence and licence conditions
- ❑ A periodic inspection report for the electrical installation
- ❑ A plan and notice setting out action to be taken in an emergency and giving emergency contacts, local doctors, environmental health department etc
- ❑ The location of the nearest public telephone
- ❑ The name and location/telephone number of the site licence holder or his/her accredited representative.
- ❑ If the site has a risk of flooding, advice about the operation of the flood warning system
- ❑ 'No Smoking' sign on any LPG store/compound
- ❑ Fire Notices on all Fire Points
- ❑ If the site has overhead electric lines, warning notices must be displayed on the supports for the lines and at the site entrance.

All notices should be suitably protected from weather and where possible out of direct sunlight.

## **19. LIFE SAVING EQUIPMENT**

- If a site is situated near to a lake, river or sea suitable life-saving equipment must be provided.
- At all sites subject to a flood risk, warning notices should be displayed giving advice about the operation of the flood warning system.

## **20. GENERAL**

- All site facilities and equipment required to be provided by these standards in connection with the site, shall be maintained in good condition and repair to the satisfaction of the city council.

## **21. MISCELLANEOUS**

- Where a site and its management met the previous version of the model standards but does not now meet the revised standards, the City Council may grant an extended period of time (not normally more than 5 years) within which the additional necessary works may be carried out.
- All new works shall comply with the revised model standards.